

Routine testing

Insert the test key into the hole at the bottom of the call point and push home. Observe routine test requirements as specified in BS5839-1 or the applicable local code.

Resetting

After testing, reset the call point by removing the test key and pushing up the front cover until it clicks home.

Earthing

An earthing plate is provided for continuity of metal conduits. This must be placed behind the back box prior to fixing the box to the wall. Metal conduits and backboxes should be connected to the equipotential safety earth locally in the hazardous area.

Important Information


The use of lubricants, cleaning solvents or petroleum based products should be avoided. The O-ring should be replaced when refitting or replacing the waterproof cover.

Transparent hinged cover

To provide additional protection against accidental operation, a transparent hinged cover with a locking tag, part no 26729-152, is available.

Please note that the call point does not conform to EN54-11:2001 when this lid is fitted and secured with the locking tag supplied.

For further information, please refer to the XP95 IS Engineering Product Guide, PP1095 available on request.



© Apollo Fire Detectors Limited 2006-2008

Apollo Fire Detectors Limited, 36 Brookside Road, Havant, Hampshire, PO9 1JR, UK
Tel: +44 (0) 23 9249 2412 Fax: +44 (0) 23 9249 2754
Email: techsales@apollo-fire.co.uk Website: www.apollo-fire.co.uk



XP95 IS Manual Call Point (EN54) Installation Guide

General

The XP95 IS Manual Call Point (EN54) is available in three versions:

- part no. 55100-940, non-isolated red Manual Call Point.
- part no. 55100-942, non-isolated yellow Manual Call Point (Not EN54).
- part no. 55100-944, non-isolated blue Manual Call Point (Not EN54).

Installation

1. Fit the backbox to a flat surface using the three fixing holes and screws provided. The cable entry holes should be in the vertical plane. The backbox can be mounted with either the single or double entry holes at the top. (Fig 1).

Note: Cable entry from the bottom of the call point is recommended if there is a possibility of moisture condensing within the conduit or cables.

2. Run the cables into the backbox and connect them to the terminal blocks as shown in Fig 2. The backbox has a terminal for inter connecting cable screen/drain wire (if used). The cable screens (functional earth) should be connected to ground at one point only normally near the CIE in the safe area.
3. If a continuity test is to be done, it should be carried out before securing the call point to the backbox (step 5).
4. Set the unit address on the DIL switch in accordance with the address table overleaf.
5. Ensure that the O-ring is correctly seated in the Manual Call Point moulding. Place the cover squarely over the backbox and carefully push the cover until the locating clips have engaged, use the 4 fixing screws to lock the cover in place. **Do not use excessive force, do not overtighten screws.**
6. To remove the cover, undo and remove the four cover fixing screws and release the four retaining clips. To do this place a large flat bladed screwdriver into the slot between the cover and backbox and gently twist until the clip disengages (Fig 3). Repeat this for the three remaining clips and pull the cover away from the backbox.

The XP95 IS Manual Call Point is a 'type A' call point and is suitable for outdoor use.

Wiring Details

To maintain the integrity of the 'type A' product it is essential that suitable cable glands be used.

Maximum Loop Current Consumption at 24V Operating temperature




Fig 1 Backbox

-20°C to +60°C (T4)
-20°C to +40°C (T5)




Fig 2 Terminal block connections and address 78 set




Fig 3 Cover removal

Operating voltage
Quiescent
Alarm Current (max LED on)
IP rating

14-22V DC
230µA
4mA
IP67

LED Indicator

☉ Illuminated red (under CIE control) when call point is operated

Commissioning

Manual call points must be installed to comply with the requirements of the ATEX directive or another applicable codes of regulations. All unused cable entry ports must be sealed using suitable stopping plugs to give the required level of ingress protection.

Ensure that a glass or deformable element is fitted to each call point before testing. Use the test key provided to check the operation of each device. An XP95 Test Set, part no. 55000-870, may be used to carry out functional testing of individual units (from the safe area only).

The test set can also perform data integrity tests of an entire system.

Note: the test key must remain inserted for at least 2 seconds to ensure the correct CIE response.

Address Setting

The address of the Manual Call Point is set using the DIL switch. All segments of the switch are set to 0 or 1, using a small screwdriver or similar tool.

A complete list of address settings is shown in the following table.

switch	DIL switch setting	DIL switch setting	DIL switch setting	DIL switch setting	DIL setting				
addr	1234567	addr	1234567	addr	1234567				
1	1000000	11	1101000	21	1010100				
2	0100000	12	0011000	22	0110100				
3	1100000	13	1011000	23	1110100				
4	0010000	14	0111000	24	0001100				
5	1010000	15	1111000	25	1001100				
6	0110000	16	0000100	26	0101100				
7	1110000	17	1000100	27	1101100				
8	0001000	18	0100100	28	0011100				
9	1001000	19	1100100	29	1011100				
10	0101000	20	0010100	30	0111100				
31	1111100	41	1001010						
32	0000010	42	0101010						
33	1000010	43	1101010						
34	0100010	44	0011010						
35	1100010	45	1011010						
36	0010010	46	0111010						
37	1010010	47	1111010						
38	0110010	48	0000110						
39	1110010	49	1000110						
40	0001010	50	0100110						
51	1100110	61	1011110	71	1110001	81	1000101	91	1101101
52	0010110	62	0111110	72	0001001	82	0100101	92	0011101
53	1010110	63	1111110	73	1001001	83	1100101	93	1011101
54	0110110	64	0000001	74	0101001	84	0010101	94	0111101
55	1110110	65	1000001	75	1101001	85	1010101	95	1111101
56	0001110	66	0100001	76	0011001	86	0110101	96	0000011
57	1001110	67	1100001	77	1011001	87	1110101	97	1000011
58	0101110	68	0010001	78	0111001	88	0001101	98	0100011
59	1101110	69	1010001	79	1111001	89	1001101	99	1100011
60	0011110	70	0110001	80	0000101	90	0101101	100	0010011
101	1010011	106	0101011	111	1111011	116	0010111	121	1001111
102	0110011	107	1101011	112	0000111	117	1010111	122	0101111
103	1110011	108	0011011	113	1000111	118	0110111	123	1101111
104	0001011	109	1011011	114	0100111	119	1110111	124	0011111
105	1001011	110	0111011	115	1100111	120	0001111	125	1011111
								126	0111111

The switch in Fig 2 shows address setting 78 as an example of how to set the address

Troubleshooting

Before investigating individual units for faults, it is important to check that the system wiring is fault free. Earth faults on data loops or interface zone wiring may cause communication errors.

Many fault conditions are the result of simple wiring errors. Check all connections to the unit. Do not overtighten screws when mounting the backbox.

Fault Finding

Problem	Possible Cause
No response or missing	Incorrect address setting Loop terminal incorrectly fitted
Alarm condition	Incorrect wiring (polarity reversed) Glass or element incorrectly fitted or broken Test key not removed